

UTILITY DEPARTMENT

- *Maintained and met DEP requirements on Water/ Wastewater plants*
- *Pulled monthly samples and Lead and Copper*
- *Did monthly DEP required DMR/MOR reports*
- *Monthly meter readings*
- *104 monthly no reads*
- *Work orders*
- *Maintained and cleaned lift stations*
- *Repaired 3 major breaks*
- *Lift station repairs*
- *Worked on WWTF sludge system, repaired packing, and did preventive maintenance*
- *Preventative maintenance at the lift stations*
- *Replaced Cl2 line at Commonwealth WTP*
- *Replaced 6 inch fire system for Best Buy*
- *13 installs for Fountain Park Phase 2*
- *Changed out TCUs on the lift station call boxes*
- *Had generators serviced*
- *Fire Hydrant flushing*
- *New check valve installed at Mt. Olive*
- *Fixed water leak at Mt. Olive Shores*
- *Dug up reuse line and 33 and Lake Margaret to find 90 degree connection for new reuse line*
- *Pulled and clean cl2 injectors*
- *Replaced sight glasses at Mt. Olive Plant*
- *Storm Water*