

UTILITY DEPARTMENT

February 2020

Summary: Water/Wastewater continued to maintain sampling of the Wastewater Treatment Plant. Continued to pull all samples for the Water Plants. All samples were in compliance. Completed monthly MORs/DMR reports for DEP. Completed monthly SWFWMD report as required. Met all of the DEP requirements.

- Started the abandonment of the well at the Reclaim Perk Ponds
- Started the replacement of the Hydropneumatic Water Tanks at Jacob's Plant
- Replaced corroded pipe at Voyles Loop
- Mowed WWTF, Water plants, Reclaim Ponds and lift stations
- Had all generators serviced by Ring Power
- All lift stations continue to have preventive maintenance. We are continuing to get all Verbatims/Auto dialers running properly. Generators are being maintained.

Service Completed

- Monthly meter reading
- No reads for the Utility Billing-120
- Work Orders-103
- Turn on-23
- Turn off-20
- Misc- 56 -(rereads, laptops, vacation turn on, TBO from shut off)
- Fire Hydrant flushing and maintenance is being done weekly
- Valve exercising is being done weekly
- Continue preventative maintenance/housekeeping is being done
- WWTF is maintained by wasting, decanting, housekeeping.

March Objectives:

Meet all DEP requirements to stay in compliance continuing to maintain work orders and locates. To get Jacob Plant up and running with new tanks. Finish the abandonment of the Well at the new Reclaim Ponds.

Submitted By: Lori Pearson, Utilities Supervisor