

# Polk City Water Plant

## 2023 Water Quality Report

### Mount Olive Estates

We are committed to ensuring the quality of your water and want you to be informed about the water services delivered to you. Our goal is to provide dependable supply of healthy drinking water. Therefore we are please to provide our Annual Water Report that describes the quality of the water you drink everyday. Information about the contaminants found in your water and how this may relate to your health. The presence of a moderate amount contaminants in drinking water within regulated standards is normal and does not indicate that the water poses a health risk. Should there be any reason for health concerns with you water, we would notify you immediately.

#### Where does your water come from?

Mount Olive Estates draws water from wells drilled into the Floridian aquifer. The sources of drinking water include rivers, lakes streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the grounds, it dissolves naturally occurring minerals and radioactive material and on pick up substances resulting from human or animal activity.

#### Why must our water have Chlorine?

Drinking water, including bottled water, may reasonably be expected to contain very small amounts some contaminants. The presence of containments does not necessarily mean that water require disinfection, so chlorine is added and a minimum contact time of fifteen minutes is provided to destroy living organisms before being delivered to you.

#### Have more questions?

If you have any questions about this report or concerns about your water utility, or want to obtain a copy of the report, please contact Lori Pearson at (863) 557-4456. We encourage our valued customers to information about their water utility.



#### Special Health Concerns

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency (The EPA's) Safety Drinking Water Hot Line at (800) 426-4791 or on-line at their website:

<http://www.epa.gov/safewater>



#### Want to learn more about Florida water?

Please visit the Florid Department of Environmental Protection (DEP) website at: <http://www.myflorida.com> Find an agency, Environmental Protection, Water, and drinking water.

We are proud to report that in 2023 our drinking water met all federal and state water quality standards.



# Possible dangerous contaminants?

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are, byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.



## Protecting your water

Florida's Department of Environmental Protection has conducted a Source Water Assessment (SWA), for all public water systems in Florida, to identify and assess any potential sources of contamination in the vicinity of your water supply. A SWA conducted for this system in 2009 found that the system's wells are at moderate risk for contamination due to the wells being located within an area of known agriculture ground water contamination, designated as a "Delineated Area" within Florida, for petroleum storage tanks and for hazardous waste. SWA report for Polk City is available at the DEP SWAPP website: [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp) or they can be obtained from Lori Pearson at (863) 557-4456.



## Vulnerable Populations

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. US EPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available on the web at:

[www.epa.gov/safewater](http://www.epa.gov/safewater) or telephone the Safe Drinking Water Hotline (800) 426-4791 for any drinking water issue.

# Attention Landlords/Property Managers!

If you are a landlord or property manager, please provide this water quality report to your residents/tenants.

## What Water Quality Acronyms and Terms To Know

In our line of work, we use a lot of acronyms. Here are some of the most common ones.

**AL (Action Level):** The concentration of a contaminant, which if exceeded, triggers treatment or other requirements that a system must follow.

**LRAA (Locational Running Annual Average):** The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

**MCL (Maximum Containment Level):** The maximum allowed is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG'S as feasible using the best available treatment technology.

**MRDL (Maximum Residual Disinfection Level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG (Maximum Residual Disinfectant Level Goal):** The level of a drinking water disinfectant below, which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**MCLG (Maximum Contaminant Level Goal):** The goal is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**ND (Non Detects):** Means not detected and indicates that the substance was not found by laboratory analysis.

**PCi/L (Picocuries Per Liter):** A measure of the radioactivity in water.

**PPB (Parts Per Billion):** Means one part by weight of analyte to 1 billion parts by weight of the water sample.

**PPM (Parts Per Million):** Means one part by weight of analyte to 1 million parts by weight of the water sample.



**Florida ID # 6532345 2023 TEST RESULTS TABLE Mount Olive Estates**

**\*\*Results in the Level Detected column for radiological and Inorganic contaminants are the highest detected level at any sampling point.**

Contaminant and Unit of Measurement	MCL Violation Yes / No	**Level Detected	MCLG	MCL	Monitoring Period Month / Year 2021	Likely Source of Contamination	
<b>Radioactive Contaminants</b>							
Alpha emitters	pCi/L	No	1.4	0	15	Jan – Dec 2015	Erosion of natural deposits
Radium 226 + Radium 228 (combined Radium)	pCi/L	No	0.5	0	5	Jan – Dec 2015	Erosion of natural deposits
Uranium	Pg/L	No	0.48	0	30	Jan – Dec 2015	Erosion of natural deposits
<b>Inorganic Contaminants</b>							
Arsenic DI(2-ETHYHEXYL)PHTHALATE	ppb	No	0.002 0.46	10 0.6ug/l	10 6 ug/L	Jan –Dec2021 July2023	Natural deposits in the earth, and agricultural or industrial practices.
Barium	ppm	No	0.0003	2	2	Jan – Dec 2021	The dissolving of natural minerals in the ground.
Antimony	ppb	No	0.00226	6	6	Jan – Dec 2021	Natural weathering of rock, industrial production, municipal waste disposal, and manufacturing processes.
Thallium	ppb	No	0.001	2	2	Jan – Dec 2021	Natural metal found in the soil.
Nitrate	ppm	No	1.19	10	10	Jan – Dec 2023	Run off from fertilizer, leaking septic tanks, sewage, and erosion from natural deposits.
Cadmium	ppb	No	0.002	5	5	Jan – Dec 2021	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Selenium	ppb	No	1.4	50	50	Jan – Dec 2021	Inorganic chemical found naturally in food and soils.
Sodium	ppm	No	8.2	n/a	160	Jan – Dec 2021	Salt water intrusion, leaching from soil.

**Chlorine Residual and Stage 2 Disinfectant / Disinfection By-Product (D / DBP) Parameters**

Chlorine – Level Detected is the highest 2023 monthly average; Range of Results is the range of (lowest to highest) monthly residual disinfectant.  
 HAA5 / TTHMs – Level Detected is the highest detected level at any sampling point. Range of Results is the range of results from lowest to highest.

Contaminant and Unit of Measurement	Dates of sampling (mo. / yr.)	MCL Violation Yes / No	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination	
Chlorine	ppm	Jan – Dec 2023	No	0.80	0.2 – 2.0	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes.
Total Trihalomethanes (TTHM)	ppb	July-Sept 2023	No	5.97	0.5	n/a	MCL = 80	By-product of drinking water disinfection.
Total Haloacetic Acid (HAA5)	ppb	July – Sept 2023	No	3.98	9.58	n/a	MCL = 60	By-product of drinking water disinfection.

**Lead and Copper (Tap Water)**

Contaminant and Unit of Measurement	Action Level Violation Yes / No	90 <sup>th</sup> Percentile Result	Number of Sampling Sites Exceeding the Action Level	MCGL	Action Level	Monitoring Period Month / Year	Likely Source of Contamination	
Copper (tap water)	ppm	No	0.154	0	1.3	AL = 1.3	June – Sept 2021	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead (tap water)	ppb	No	0.003	0	15	15	June – Sept 2021	Corrosion of household plumbing systems, public water systems, and erosion of natural deposits.

**The Safe Drinking Water Act (SDWA) requires utilities Issue to the following Information, even if you have no Lead in your water:**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Blue Jay Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of material used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Why is Drinking Water Regulated?**

In order to ensure that tap water is safe to drink, the DEP and EPA prescribe regulations and standards for limiting the amount of certain contaminants in water provided by public water systems. To protect consumers, Florida's DEP also requires public water systems comply with regulations governing the construction, operation and health issues relative to your water supply. MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect of some contaminants. Don't forget, the presence of contaminants does not necessarily indicate that the water poses a health risk. Bottled water and water vending machines are regulated under the Florida Department of Agriculture and Consumer Services, Division of Food Safety and the federal Food and Drug Administration regulations that establish limits for contaminants in bottled water which must provide the same protection for public health. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Don't forget, the presence of contaminants does not necessarily indicate that the water poses a health risk.